



GROUP: CIVIL/STRUCTURAL ENGINEERING

GUIDE NO.: EG-19.0

SUBJECT: Pipe Supports Design

ISSUE DATE: 12 SEP 06

RESPONSIBLE ENGINEER: D. Mueller

Approved: 10 DEC 99

TABLE OF CONTENTS

| | <u>Page</u> |
|--|--------------------|
| I. <u>General</u> | 2 |
| II. <u>Design Loads</u> | 2 |
| A. Vertical Loads | 2 |
| B. Horizontal Loads | 3 |
| C. Load Combinations | 3 |
| III. <u>Structural Design</u> | 4 |
| IV. <u>Typical Piperack Configuration</u> | 7 |
| <u>Design Example</u> | 20 Pgs |



I. General

This guide presents a general approach for the analysis and design of pipe supports, including main racks, miscellaneous and “T” supports.

II. Design Loads

A. Vertical Loads

1. Piping

- a. Main Rack – Vertical loads due to piping shall be the average unit loading at each level as determined from the piping layout drawings, but not less than 30 psf (22 psf dead load and 12 psf live load) per level.
- b. Miscellaneous Racks and “T” Supports - Vertical loads due to piping shall be the average unit loading at each level as determined from the piping layout drawings, but not less than 20 psf (16 psf dead load and 4 psf live load) per level.
- c. Pipes 14 inches and larger in diameter shall be considered as a concentrated load.

2. Electrical

Use a minimum of 20 psf (dead load) (for the width of the tray or area width of conduits) per level for conduits and single level cable trays. Use a minimum of 40 psf for double level cable trays.

3. Equipment

Loads should be obtained from vendor drawings for all equipment, such as air coolers with associated walkways and platforms.

4. Live

Apply per the job specifications to all walkways, platforms, stairs, and ladders. A 20% reduction in live load is allowed when in combination with full wind or seismic. This reduction does not apply to piping live load (fluid load) or snow loads. Snow loading shall be included on platforms, cable trays, and equipment where applicable.



◦. Hydrotest

Combine the hydrotest load of vapor lines with dead load only from the other piping lines.

∩. Structure

Include the weight of all structural members, stairs, platforms and fireproofing in design.

B. Horizontal Loads

∩. Wind

Apply wind loads to the structure, piping and equipment per *EG-19.01*. Use $\frac{1}{4}$ in. diameter piping, minimum, if sizes are not known.

∩. Seismic

Calculate seismic loads to the structure, piping and equipment per *EG-19.02*. Use critical wind or seismic loads in design.

∩. Friction

Use a longitudinal friction force equal to 10 % of the applied piping vertical load at each support level.

∩. Anchor and Guide

Anchor and guide forces, provided by the pipe stress group, may require horizontal bracing in the affected bay and may control the placement of vertical bracing.

C. Load Combinations

∩. Design pipe supports to accommodate the following load combinations:

- a. Dead + Live
- b. Dead + Wind (or Seismic)
- c. Dead + Live + Wind (or Seismic)
- d. Dead + Live + Friction (or Anchor and Guide)
- e. Dead + Live + Anchor and Guide + Wind (or Seismic)



III. Structural Design

- A. Design pipe racks as rigid frames in the transverse direction, with fixed bases. Struts transfer longitudinal loads to braced bays.
- B. Use computer program such as Staad-Pro to perform a rigid frame analysis. (See example for typical input file.)
- C. Make no allowance for future support levels unless specifically called for by the job scope. Apply minimum loads on empty areas of partially loaded supports per section II of this guide to account for future pipe loading.
- D. Satisfy the applicable seismic requirements also, when other loads control design.
- E. Limit lateral deflection of piperack bent to $L/100$.
- F. Limit lateral deflection at anchor points to $\frac{1}{2}$ inch under anchor load only. Use 50% of the moment of inertia of the beam when the anchor load is along the weak axis of the beam.
- G. Following are some of the necessary parameters required for individual member design. Only those criteria, which are peculiar to pipe supports or have been known to cause confusion in their selection, are listed.

1. Columns

- a. Strong direction (i.e. weak axis) oriented perpendicular to piping.
- b. Effective Length Factor "K" :

| TYPE OF SUPPORT | X-X (STRONG) | Y-Y (WEAK) |
|--|--------------|------------|
| Piperack with struts And vertical bracing | 1.2* | 1.0 |
| Single frame | 1.2* | 1.6** |
| "T" Support | 2.1 | 1.8** |

* For more accurate value use alignment charts, ASD 9th Ed., pp 2-137, Fig. C-C7.7

** Assumes partial restraint/support from piping

2. Transverse Beams

- a. Reduce weak axis section modulus by 50 % when designing for Friction loads.
- b. For calculating allowable strong axis bending (consider that the moment curve inflection points may be considered as locations of



lateral support for the compression flange, use $\frac{1}{2}$ span as the unbraced length. Otherwise, consider the whole span to be laterally unbraced.

- c. Maintain as much uniformity as is reasonable in member selection and moment connection details.

ϣ. Longitudinal Struts

- a. Design the strut beam for the larger of :

1. Actual loading from pipe.
2. Pipe rack loadings as given in section II.A.1, multiplied by $\frac{1}{2}$ of the piperack width. (ex. 30 psf x 10 x 20 ft for a 20 ft wide rack).

- b. Design all longitudinal struts to carry applied axial forces.

- c. Strut load from pipe (dead + live) is not normally input into frame analysis of bent, but lead engineer may want to consider inputting 1 level on a multilevel strut rack.

- d. To isolate a portion of the rack from existing structure or another rack, slot connections at strut ends

- e. Use $\frac{2}{3}$ of length for unbraced length when considering vertical beam load and/or axial load.

ε. Vertical Bracing (Longitudinal)

- a. Bracing usually consists of WT or double angle sections in an inverted "V" (chevron bracing) configuration.

- b. Locate braced bays at approximately 100 ft. intervals. Preferably provide two braced bays in each column row at every independent section of rack. But in no case should there be less than one braced bay in each column row, unless an alternate means of longitudinal support is provided.

- c. Size bracing for the largest load applied by the following :

1. Accumulative force from friction.
2. Longitudinal component of the wind acting at an angle of $\leq 90^\circ$ to the pipe rack.
3. Anchor Forces.





- ε. Longitudinal seismic forces.
- ο. Moment Connections
 - a. Provide end-plate moment connections in transverse beams.
 - b. Consider using heavier column section in lieu of doubler plates when column web panel shear is exceeded.
 - c. Design beam moment connections for the full beam capacity ($.16F_y$ moment)
- ϖ. Air Cooler Support Girders
 - a. Analyze as continuous beam spanning across tops of columns. Avoid lateral beams and horizontal bracing unless girder size becomes excessive.
 - b. Space air coolers to allow piperack column to extend above the air coolers for header pipe support.
 - c. Use 140 psf for preliminary frame design without vendor weights. Base final design of girder on actual vendor provided weights, or use from 'd'.
 - d. Typical Air Cooler Loads (For estimating only)
(Loads shown on pipe support column)

| | | | |
|--|-----------------|-----------------|-----------------|
| Piperack Width | 20' | 20' | 30' |
| Dead Load | 30 k/col | 42 k/col | 50 k/col |
| Live Load | 3.0 k/col | 4 k/col | 5 k/col |
| Wind Load | | | |
| Traverse Shear | 0 k/col | 0.0 k/col | 6 k/col |
| Wind Couple, Vertical | ± 4.0 k/col | ± 4.0 k/col | ± 4.0 k/col |
| Longitudinal Shear (at braced bay only) | 18 k/bay | 18 k/bay | 18 k/bay |


Note: Wind loads are based on a design wind speed of 110 mph. For other design wind speed, V , multiply wind loads above by $V^2/110^2$.




IV. Typical Piperack Configuration




TYPICAL BENT
SECTION A-A



LONGITUDINAL SECTION B-B



TYPICAL PIPE BRIDGE
Figure 1



MISCELLANEOUS PIPE SUPPORTS
Figure 7



TABLE OF CONTENTS

| | <u>Page</u> |
|---|--------------------|
| 1. Sketches | 2 |
| 2. Problem/Design Criteria | 5 |
| 3. Dead Loads | 6 |
| 4. Fluid Loads | 9 |
| 5. Live Loads | 11 |
| 6. Wind Loads | 12 |
| 7. Friction Loads | 15 |
| 8. Strut Design | 16 |
| 9. Air Cooler Longitudinal Support Design | 17 |
| 10. Longitudinal Bracing Design | 18 |
| 11. Staad Model | 21 |



VIII. Design Example






FIGURE 1
ELEVATION OF A TYPICAL BENT
LOOKING WEST





DETAIL 1



Problem:

Design the pipe rack illustrated in figures 1 and 2 using STAAD III. Figures 1 and 2 show typical information available at the beginning of a job, usually provided by the Piping Department.

Given Design Criteria:

- a) Wind ASCE 7-93 – 110 mph, Exposure C, Importance Factor 1.0.
- b) Seismic Zone 4
- c) Air Cooler Loads (obtained from Mech/Equip. vendor drawings)

Dead Load = 130 psf (based on plan area of rack)

Fluid Load = 20 psf (based on plan area of rack)

Live Load = 10 psf (based on plan area of rack)

* Note: Actual Air Cooler loads should be used to check the final design when they become available.

- d) No future expansion is considered in design.
- e) All members are fireproofed except the longitudinal struts, and the top most transverse beam, which is included for platform support.
- f) Engineering Guide EG-1900



Load calculations for STAAD-III model:

Dead Loads

Air Coolers:

Air cooler load per column

$$= \frac{(20 \text{ ft})^2}{2} \left(\frac{130 \text{ lbs}}{\text{ft}^2} \right) = 26 \text{ kips}$$

$$30'' \text{ Header Pipe} = \frac{118.8 \text{ lbs}}{\text{ft}}$$

(Ref. EG-1900 IV. Weight of Pipes)

Column load due to 30'' Header Pipe

$$= \frac{118.8 \text{ lbs}}{\text{ft}} (20 \text{ ft}) = 2.376 \text{ kips}$$

Structure:

Weight of each W10x16 Longitudinal Strut on each column

$$= 20 \text{ ft} \left(\frac{26 \text{ lbs}}{\text{ft}} \right) = 0.52 \text{ kips}$$

Weight of W10x16 A/C support beam plus fireproofing

$$= 20 \text{ ft} \left(\frac{67 \text{ lbs} + 251 \text{ lbs}}{\text{ft}} \right) = 6.8 \text{ kips} \quad (\text{Ref.????})$$

$$\text{Column fireproofing load} = \frac{244 \text{ lbs}}{\text{ft}} = 0.244 \frac{\text{kips}}{\text{ft}} \quad (\text{Ref.????})$$

Traverse beam fireproofing load

$$W10x16 = \frac{252 \text{ lbs}}{\text{ft}} = 0.252 \frac{\text{kips}}{\text{ft}} \quad (\text{Ref.????})$$

$$W10x11 = \frac{213 \text{ lbs}}{\text{ft}} = 0.213 \frac{\text{kips}}{\text{ft}} \quad (\text{Ref.????})$$

Upper level piping (Elevation 122'-0''):

Minimum piping load on first 12 ft

(Ref. EG-1900, pg. 2, II.A.1.a)

$$= 20 \text{ ft} \left(\frac{22 \text{ lbs}}{\text{ft}^2} \right) = \frac{0.44 \text{ kips}}{\text{ft}}$$

Minimum load due cable tray on final 12 ft

(Ref. EG-1900, pg. 2, II.A.2)

$$= 20 \text{ ft} \left(\frac{20 \text{ lbs}}{\text{ft}^2} \right) = \frac{0.40 \text{ kips}}{\text{ft}}$$

Concentrated load due to 36'' FLR

(Ref. EG-1900 IV. Weight of Pipes)

(Ref. EG-1900, pg. 2, II.A.1.c)

$$= \frac{142.8 \text{ lbs}}{\text{ft}} \times 20 \text{ ft} - \left(3 \text{ ft} \times \frac{0.44 \text{ kips}}{\text{ft}} \right) = 1.536 \text{ kips}$$

Mid level piping (Elevation 124'-0''):

Minimum piping load

$$= 20 \text{ ft} \left(\frac{22 \text{ lbs}}{\text{ft}^2} \right) = \frac{0.44 \text{ kips}}{\text{ft}}$$

Concentrated loads due to 30'' CWS and 30'' CWR (Ref. EG-1900 IV. Weight of Pipes)

$$= \frac{118.8 \text{ lbs}}{\text{ft}} \times 20 \text{ ft} - \left(2.5 \text{ ft} \times \frac{0.44 \text{ kips}}{\text{ft}} \right) = 1.276 \text{ kips}$$

Lower level piping (Elevation 118'-0'')



Minimum piping load

$$= 20 \text{ ft} \left(\frac{22 \text{ lbs}}{\text{ft}^2} \right) = \frac{0.44 \text{ kips}}{\text{ft}}$$

Concentrated loads due to Insulated 16" STM


(Ref. EG-1900 IV. Weight of Pipes)

(Ref. EG-1900 V. Weight of Piping Insulation)

$$= \left(\frac{62.6 \text{ lbs}}{\text{ft}} + 1.01 \text{ ft}^2 \left(\frac{12 \text{ lbs}}{\text{ft}^3} \right) \right) \times 20 \text{ ft} - \left(1.33 \text{ ft} \times \frac{440 \text{ lbs}}{\text{ft}} \right) = 0.909 \text{ kips}$$



DEAD LOAD





Fluid Loads

Air Coolers:

Air cooler load per column

$$= \frac{(20 \text{ ft})^2}{2} \left(\frac{20 \text{ lbs}}{\text{ft}^2} \right) = 4 \text{ kips}$$

$$30'' \text{ Header Pipe} = \frac{291.2 \text{ lbs}}{\text{ft}} \quad (\text{Ref. EG-1900 IV. Weight of Pipes})$$

Column load due to 30'' Header Pipe

$$= \frac{291.2 \text{ lbs}}{\text{ft}} (20 \text{ ft}) = 5.824 \text{ kips}$$

Upper level piping (Elevation 132'-0''):

Minimum piping load on first 20 ft

$$= 20 \text{ ft} \left(\frac{13 \text{ lbs}}{\text{ft}^2} \right) = \frac{0.26 \text{ kips}}{\text{ft}}$$

Concentrated load due to 36'' FLR (Ref. EG-1900 IV. Weight of Pipes)

$$= \frac{422.9 \text{ lbs}}{\text{ft}} \times 20 \text{ ft} - \left(3 \text{ ft} \times \frac{0.26 \text{ kips}}{\text{ft}} \right) = 7.678 \text{ kips}$$

Mid level piping (Elevation 124'-0''):

Minimum piping load

$$= 20 \text{ ft} \left(\frac{13 \text{ lbs}}{\text{ft}^2} \right) = \frac{0.26 \text{ kips}}{\text{ft}}$$

Concentrated loads due to 30'' CWS and 30'' CWR (Ref. EG-1900 IV. Weight of Pipes)

$$= \frac{291.2 \text{ lbs}}{\text{ft}} \times 20 \text{ ft} - \left(2.5 \text{ ft} \times \frac{0.26 \text{ kips}}{\text{ft}} \right) = 5.174 \text{ kips}$$

Lower level piping (Elevation 118'-0''):

Minimum piping load


$$= 20 \text{ ft} \left(\frac{13 \text{ lbs}}{\text{ft}^2} \right) = \frac{0.26 \text{ kips}}{\text{ft}}$$

Concentrated loads due to Insulated 16'' STM (Ref. EG-1900 IV. Weight of Pipes)

$$= \frac{79.2 \text{ lbs}}{\text{ft}} \times 20 \text{ ft} - \left(1.33 \text{ ft} \times \frac{0.26 \text{ kips}}{\text{ft}} \right) = 1.238 \text{ kips}$$



FLUID LOAD



* ENGR MAY ELECT TO INPUT
LIVE LOAD FROM PIPE ON
STRUT.




Live Loads

Air Coolers:

Air cooler load per column

$$= \frac{(20 \text{ ft})^2}{2} \left(\frac{10 \text{ lbs}}{\text{ft}^2} \right) = 2 \text{ kips}$$

LIVE LOAD





Wind Loads

Note:

$$F = A_f \times G_h \times C_f \times q$$

Overall height = 40 ft + 19 ft = 59 ft, implies $G_h = 1.20$ (Ref. EG-1901, pg. 10, Table 11)

to 20 ft $q = \frac{26.9lbs}{ft^2}$ (Ref. EG-1901, pg. 14, Table 6)

20 to 40 ft $q = \frac{30.3lbs}{ft^2}$ (Ref. EG-1901, pg. 14, Table 6)

40 to 60 ft $q = \frac{35.0lbs}{ft^2}$ (Ref. EG-1901, pg. 14, Table 6)

Air Coolers:

For Wind on Equipment $C_f = 1.3$ (Ref. EG-1901, pg. 23, Table 11)

Effective Height of air cooler

$$h_{e1} = \text{Header Pipe Diameter} = 3 \text{ in}$$

$$h_{e2} = \text{Actual Bundle height} = 7 \text{ ft}$$

$$h_{e3} = 0.0\% \times \text{Actual height of the coolers base support} = 0.0\% \times 1 \text{ ft} = 0 \text{ ft}$$

$$H_{eff} = \text{total effective height of the air cooler} = h_{e1} + h_{e2} + h_{e3} = 10 \text{ ft}$$

Horizontal wind load per bent

$$F = 12.5 \text{ ft} \times 20 \text{ ft} \times 1.20 \times 1.3 \times 35 \text{ lbs/ft}^2 = 13.650 \text{ kips}$$

Value applied to the tops of each column.

$$= \frac{13.650 \text{ kips}}{2 \text{ columns}} = 6.825 \frac{\text{kips}}{\text{column}}$$

Vertical wind load per column

Assume the horizontal wind force acts 2/3 of the effective height above the top most traverse beam.

$$= \frac{13.650 \text{ kips} \times (2/3) \cdot 10 \text{ ft}}{20 \text{ ft}} = \pm 5.688 \text{ kips}$$

Value is positive (+) on the windward column and negative (-) on the leeward column.

Structure:

For Wind on Windward Steel $C_f = 1.8$ (Ref. EG-1901, pg. 23, Table 11)

(Ref. EG-1901, pg. 20, Note 3)

For Wind on Leeward Steel $C_f = 1.5$

(Ref. EG-1901, pg. 23, Table 11)

(Ref. EG-1901, pg. 20, Note 3)

Columns up to 20 ft

Uniform load on the windward column:

$$F = \frac{(10 \text{ in} + 2 \text{ in} \times 2) \text{ ft}}{12 \text{ in}} \times 1.20 \times 1.8 \times \frac{26.9 \text{ lbs}}{\text{ft}^2} = 0.068 \frac{\text{kips}}{\text{ft}}$$

Uniform load on the leeward column:

$$F = \frac{(10 \text{ in} + 2 \text{ in} \times 2) \text{ ft}}{12 \text{ in}} \times 1.20 \times 1.5 \times \frac{26.9 \text{ lbs}}{\text{ft}^2} = 0.056 \frac{\text{kips}}{\text{ft}}$$

Columns 20 ft to 40 ft:

Uniform load on the windward column:

$$F = \frac{(10 \text{ in} + 2 \text{ in} \times 2) \text{ ft}}{12 \text{ in}} \times 1.20 \times 1.8 \times \frac{30.3 \text{ lbs}}{\text{ft}^2} = 0.076 \frac{\text{kips}}{\text{ft}}$$

Uniform load on the leeward column:



$$F = \frac{(10in + 2in \times 2)ft}{12in} \times 1.20 \times 1.5 \times \frac{30.3lbs}{ft^2} = 0.064 \frac{kips}{ft}$$

Lower Strut (Elevation 11'-0"):

Concentrated load on the windward column at the strut elevation:

$$F = \frac{(10in)ft}{12in} \times 20ft \times 1.20 \times 1.8 \times \frac{26.9lbs}{ft^2} = 0.968kips$$

Concentrated load on the leeward column at the strut elevation:

$$F = \frac{(10in)ft}{12in} \times 20ft \times 1.20 \times 1.5 \times \frac{26.9lbs}{ft^2} = 0.807kips$$

Mid and Upper Strut (Elevation 12'-0" and 14'-0"):

Concentrated load on the windward column at the strut elevation:

$$F = \frac{(10in)ft}{12in} \times 20ft \times 1.20 \times 1.8 \times \frac{30.3lbs}{ft^2} = 1.091kips$$

Concentrated load on the leeward column at the strut elevation:

$$F = \frac{(10in)ft}{12in} \times 20ft \times 1.20 \times 1.5 \times \frac{30.3lbs}{ft^2} = 0.909kips$$

Air Cooler Support Beams (Elevation 14'-0"):

Concentrated load on the windward column at the beam elevation:

$$F = \frac{(16in)ft}{12in} \times 20ft \times 1.20 \times 1.8 \times \frac{30.3lbs}{ft^2} = 1.745kips$$

Concentrated load on the leeward column at the beam elevation:

$$F = \frac{(16in)ft}{12in} \times 20ft \times 1.20 \times 1.5 \times \frac{30.3lbs}{ft^2} = 1.454kips$$

Piping:

For Wind on Piping $C_f = 0.7$

(Ref. EG-1901, pg. 23, Table 11)

The projected area for piping shall be based on the diameter of the largest pipe plus 10 percent of the width of the piperack times the length of the pipes. (Ref. EG-1901, pg. 20, Note J)

Lower Level Piping:

Concentrated load split between the windward and leeward column applied at the supporting beam elevation:

$$F = \left(\frac{16in + 2in \times 2}{12in/ft} + 10\% \times (20ft) \right) \times 20ft \times 1.20 \times 0.7 \times \frac{26.9lbs}{ft} = 1.657kips$$

Mid Level Piping:

Concentrated load split between the windward and leeward column applied at the supporting beam elevation:

$$F = \left(\frac{30in}{12in/ft} + 10\% \times (20ft) \right) \times 20ft \times 1.20 \times 0.7 \times \frac{30.3lbs}{ft} = 2.727kips$$


Upper Level Piping:

Concentrated load split between the windward and leeward column applied at the supporting beam elevation:

$$F = \left(\frac{36in}{12in/ft} + 10\% \times (20ft) \right) \times 20ft \times 1.20 \times 0.7 \times \frac{30.3lbs}{ft} = 2.545kips$$



WIND LOAD NORTH TO SOUTH





Friction Load

Note: The load is doubled to account for reducing S_y by half. (Ref. EG-1909, pg. 2, III.C.2.a)
Use a longitudinal force equal to 10% of the applied piping vertical load at each support level. At points of concentrated pipe loads use 30% of applied vertical load. (Ref. EG-1909, II.B.2)

Uniform load on each transverse beam:

$$\omega = 2 \times \left(0.44 \frac{\text{kips}}{\text{ft}} + 0.26 \frac{\text{kips}}{\text{ft}} \right) \times 10\% = 0.140 \frac{\text{kips}}{\text{ft}}$$

Concentrated Load due to 36" FLR line on upper beam (no water):

$$F_1 = 2 \times (1.536 \text{kips}) \times 30\% = 0.922 \text{kips}$$

Concentrated Load due to 30" CWS & 30" CWR line on middle beam:


$$F_2 = 2 \times (1.276 \text{kips} + 5.174 \text{kips}) \times 30\% = 3.87 \text{kips}$$

Concentrated Load due to 16" STM line on upper beam (no water):

$$F_3 = 2 \times (0.909 \text{kips}) \times 30\% = 0.545 \text{kips}$$



FRICTION LOAD



Design Calculations:

Verify Strut Design:

Strut size: W10x26

Properties:

| | | | |
|----------------|------------------------|------------------|------------------|
| $r_t = 1.54in$ | $\frac{d}{A_f} = 4.07$ | $S_x = 27.9in^3$ | $S_y = 4.89in^3$ |
| $C_b = 1.0$ | $F_y = 36ksi$ | $l = 20ft$ | |

Loads:

Vertical load

Self weight of the beam = 26 lbs/ft

Weight of pipe = 26 psf x 20 ft x 0.0 = 300 lbs/ft

Total vertical load = 26 lbs/ft + 300 lbs/ft = 326 lbs/ft

(Ref. EG-1900, pg.2, III.G.3)



Horizontal load

$$\text{Friction Load} = 1.0\% \times 3600 \cdot \text{lbs/ft} = 36 \text{ lbs/ft}$$

(Ref. ????)

Calculations:

$$\frac{l}{r_t} = \frac{20 \text{ ft}}{1.54 \text{ in}} \times \frac{12 \text{ in}}{\text{ft}} = 155.844 \geq \sqrt{\frac{510 \times 10^3 C_b}{F_y}} = 119.02$$

$$F_{bx} = \frac{170 \times 10^3 C_b}{(l/r_t)^2} \leq 0.6 F_y \quad F_{bx} = \frac{170 \times 10^3}{(119.02)^2} = 7 \text{ ksi} \quad (\text{Ref. AISC-ASD F1-7})$$

$$F_{bx} = \frac{12 \times 10^3 C_b}{(ld/A_f)} \leq 0.6 F_y \quad F_{bx} = \frac{12 \times 10^3}{\left(20 \text{ ft} \times \frac{12 \text{ in}}{\text{ft}}\right) \times 4.07} = 12.285 \text{ ksi} \quad (\text{Ref. AISC-ASD F1-8})$$

$$F_{bx} = 12.285 \text{ ksi} \quad \dots \text{Controls}$$

$$F_{by} = 0.75 F_y = 27 \text{ ksi} \quad (\text{Ref. AISC-ASD F1-1})$$

$$M_x = \frac{(376 \text{ lbs/ft}) \times (20 \text{ ft})^2}{8} = 18.8 \text{ kip} \cdot \text{ft}$$

$$M_y = \frac{(35 \text{ lbs/ft}) \times (20 \text{ ft})^2}{8} = 1.75 \text{ kip} \cdot \text{ft}$$

$$f_{bx} = \frac{M_x \times \frac{12 \text{ in}}{\text{ft}}}{S_x} = 8.086 \text{ ksi}$$

$$f_{by} = \frac{M_y \times \frac{12 \text{ in}}{\text{ft}}}{S_y} = 4.294 \text{ ksi}$$

$$\text{Stress Ratio} = \frac{f_{bx}}{F_{bx}} + \frac{f_{by}}{F_{by}} = \frac{8.086 \text{ ksi}}{12.285 \text{ ksi}} + \frac{4.294 \text{ ksi}}{27 \text{ ksi}} = 0.82 \leq 1.0 \quad \dots \text{O.K.} \quad (\text{Ref. AISC-ASD H1-3})$$

Preliminary Design Size $W10 \times 26$ for Struts

*Note: When the piping arrangement is finalized, individual struts may require further inspection, especially for axial loads from wind.



Verify Air Cooler Longitudinal Support Beam Design:

Beam size: W12x14

Properties:

$$r_t = 2.75in \quad \frac{d}{A_f} = 2.4 \quad S_x = 117.0in^3 \quad S_y = 23.2in^3$$

$$C_b = 1.0 \quad F_y = 36ksi \quad l = 20ft$$

Loads:

Horizontal load

Load due to the wind on the Air Cooler

$$F = 12.5ft \times 20ft \times 1.20 \times 1.3 \times 35lbs/ft^2 = 13.650kips \quad (\text{Ref. Previous calculation})$$

Note: For the 20 ft span between bents the Air Coolers have 3 contact points along each longitudinal support beam

The component applied at the mid-span of the beam is

$$= \frac{13.650kips}{2 \text{ beams}} / 2 = 3.413kips$$

Vertical load

Self weight of the beam plus the fireproofing = 14 lbs/ft + 261 lbs/ft = 275 lbs/ft

Load due to the wind on the Air Cooler

$$= \frac{13.650kips \times (2/3)12.5ft}{20ft} = \pm 5.688kips \quad (\text{Ref. Previous calculation})$$

The component applied at the mid-span of the beam is

$$= \frac{5.688kips}{2 \text{ beams}} = 2.844kips$$

Weight of the Air Coolers (Dead+Fluid+Live) applied at mid-span of the support beam is

$$= \left(\frac{20ft}{2} \times \frac{20ft}{2} \right) \times (130 + 20 + 10) \frac{lbs}{ft^2} = 16kips$$

Calculations:

$$\sqrt{\frac{102 \times 10^3 C_b}{F_y}} = 53.23 \leq \frac{l}{r_t} = \frac{20ft}{2.75in} \times \frac{12in}{ft} = 87.273 \leq \sqrt{\frac{510 \times 10^3 C_b}{F_y}} = 119.02$$

$$F_{bx} = \left[\frac{2}{3} - \frac{F_y(l/r_t)^2}{1530 \times 10^3 C_b} \right] \leq 0.6F_y \quad F_{bx} = \left[\frac{2}{3} - \frac{36(87.237)^2}{1530 \times 10^3} \right] = 17.548ksi \quad (\text{Ref. AISC-ASD F1-7})$$

$$F_{bx} = \frac{12 \times 10^3 C_b}{(ld/A_f)} \leq 0.6F_y \quad F_{bx} = \frac{12 \times 10^3}{\left(20ft \times \frac{12in}{ft} \right) \times 2.4} = 20.833ksi \quad (\text{Ref. AISC-ASD F1-8})$$

$$F_{bx} = 20.833ksi \quad \dots \text{Controls}$$

$$F_{by} = 0.75F_y = 27ksi \quad (\text{Ref. AISC-ASD F1-1})$$

a) Operating

$$M_x = \frac{16,000lbs \times 20ft}{4} + \frac{(328lbs/ft) \times (20ft)^2}{8} = 96.4kip \cdot ft$$

$$f_{bx} = \frac{M_x \times \frac{12in}{ft}}{S_x} = 9.877ksi \quad \dots \text{less than } F_{bx} \quad \text{O.K.}$$



b) Operating + Wind

$$M_x = M_x + \frac{2,844\text{lbs} \times 20\text{ft}}{4} = 110.62\text{kip} \cdot \text{ft}$$

$$M_y = \frac{3.413\text{kips} \times 20\text{ft}}{4} = 17.07\text{kips}$$

$$f_{bx} = \frac{M_x \times \frac{12\text{in}}{\text{ft}}}{S_x} = 11.35\text{ksi}$$

$$f_{by} = \frac{M_y \times \frac{12\text{in}}{\text{ft}}}{S_y/2} = 17.65\text{ksi}$$

$$\text{Stress Ratio} = \frac{f_{bx}}{F_{bx}} + \frac{f_{by}}{F_{by}} = \frac{11.35\text{ksi}}{20.833\text{ksi}} + \frac{17.65\text{ksi}}{27\text{ksi}} = 1.20 \leq 1.33 \quad \dots \text{O.K. (Ref. AISC-ASD H1-3)}$$

Preliminary Design Size W14x14 for Longitudinal Air Cooler Support Beams

Design the Longitudinal Bracing

To develop the quarter wind factor, assume the total wind on one bent is unity.
Take the longitudinal component of the wind at ϵ° degrees to the rack.




FIGURE 3

Lateral Wind = 1kip/bent (Unity)



$$H_{prime} = \left(\frac{1 \text{ kip} / \text{ bent}}{20 \text{ ft}} \right) \times (20 \text{ ft} \times \text{Cos}45^\circ) = 0.707 \text{ kips} / \text{ bent}$$

$$H_1 = H_{prime} \times \text{Cos}45^\circ = 0.5 \text{ kips} / \text{ bent} \quad \text{Longitudinal component of the quarter wind}$$

The horizontal wind at each column line is

$$H = \frac{H_1}{2} = 0.25 \text{ kips} / \text{ bent}$$

The quarter wind factor for the total wind per braced bay is

$$F = H \times \frac{\text{number of bents} - 1}{\text{number of braced bays}} = 0.25 \frac{\text{kips}}{\text{ bent}} \times \frac{(9 - 1) \text{ bents}}{2 \text{ braced bays}} = 1 \frac{\text{ kip}}{\text{ braced bay}}$$

This is the force per kip of lateral wind.

Brace Lengths

(Ref. Figure 1, 2, and 3)

$$L_1 = \sqrt{(140 \text{ ft} - 128 \text{ ft})^2 + (10 \text{ ft})^2} = 15.62 \text{ ft}$$

$$L_2 = \sqrt{(128 \text{ ft} - 121 \text{ ft})^2 + (10 \text{ ft})^2} = 12.207 \text{ ft}$$

$$L_3 = \sqrt{(121 \text{ ft} - 115 \text{ ft})^2 + (10 \text{ ft})^2} = 11.662 \text{ ft}$$

$$L_4 = \sqrt{(115 \text{ ft} - 101 \text{ ft})^2 + (10 \text{ ft})^2} = 17.205 \text{ ft}$$




FIGURE 4
ELEVATION OF A TYPICAL BRACED
BAY LOOKING SOUTH

Brace Loads

(Ref. Wind Load Calculations)

Load = Hor. Wind on the Air Cooler + Wind on the Air Cooler Support Beams + Wind on the Columns

$$Load = 13.650\text{kips} + (1.745\text{kips} + 1.454\text{kips}) + \left(0.076 \frac{\text{kips}}{\text{ft}} + 0.064 \frac{\text{kips}}{\text{ft}}\right) \times 6\text{ft} = 17.69\text{kips}$$

$$Brace Load_1 = \frac{Load \times F}{2 \text{ braces}} \times \frac{15.62\text{ft}}{10\text{ft}} = 13.82\text{kips}$$

Load = Load + Wind on the Upper Level Piping + Wind on the Upper Level Struts + Wind on the Columns

$$Load = 17.69\text{kips} + 2.545\text{kips} + (1.091\text{kips} + 0.909\text{kips}) + \left(0.076 \frac{\text{kips}}{\text{ft}} + 0.064 \frac{\text{kips}}{\text{ft}}\right) \times 9.5\text{ft} = 23.56\text{kips}$$

$$Brace Load_2 = \frac{Load \times F}{2 \text{ braces}} \times \frac{12.207\text{ft}}{10\text{ft}} = 14.38\text{kips}$$

Load = Load + Wind on the Mid Level Piping + Wind on the Mid Level Struts + Wind on the Columns



$$Load = 23.56kips + 2.727kips + (1.091kips + 0.909kips) + \left(0.076 \frac{kips}{ft} + 0.064 \frac{kips}{ft} \right) \times 6.5 ft = 29.20kips$$

$$Brace Load_3 = \frac{Load \times F}{2 braces} \times \frac{11.662 ft}{10 ft} = 17.03kips$$

Load = Load + Wind on the Lower Level Piping + Wind on the Lower Level Struts + Wind on the Columns

$$Load = 29.20kips + 1.657kips + (0.968kips + 0.807kips) + \left(0.068 \frac{kips}{ft} + 0.056 \frac{kips}{ft} \right) \times 10 ft = 33.87kips$$

$$Brace Load_4 = \frac{Load \times F}{2 braces} \times \frac{17.205 ft}{10 ft} = 29.14kips$$


To size braces, reference AISC Columns – Allowable Axial Loads, p. 3-86
(1/3 increase allowable for wind)

For lengths 1, 2, and 3 select WT 12x9

For length 4 select WT 10x11



STAAD JOINT and MEMBER NUMBERS





STAAD 7D INPUT FILE

STAAD SPACE EG-19.0 STANDARD PIPERACK DESIGN EXAMPLE

INPUT WIDTH 77

*MUSTANG ENGINEERS AND CONSTRUCTORS, INC.

*FILE EG19.0.STD

OUTPUT WIDTH 77

UNIT FEET KIP

JOINT COORDINATES

| | | | |
|----|--------|--------|------|
| 1 | .000 | .000 | .000 |
| 2 | .000 | 13.000 | .000 |
| 3 | .000 | 16.000 | .000 |
| 4 | .000 | 19.000 | .000 |
| 5 | .000 | 22.000 | .000 |
| 6 | .000 | 26.000 | .000 |
| 7 | .000 | 30.000 | .000 |
| 8 | .000 | 38.000 | .000 |
| 9 | 20.000 | .000 | .000 |
| 10 | 20.000 | 13.000 | .000 |
| 11 | 20.000 | 16.000 | .000 |
| 12 | 20.000 | 19.000 | .000 |
| 13 | 20.000 | 22.000 | .000 |
| 14 | 20.000 | 26.000 | .000 |
| 15 | 20.000 | 30.000 | .000 |
| 16 | 20.000 | 38.000 | .000 |

MEMBER INCIDENCES

| | | |
|----|----|----|
| 1 | 1 | 2 |
| 2 | 2 | 3 |
| 3 | 3 | 4 |
| 4 | 4 | 5 |
| 5 | 5 | 6 |
| 6 | 6 | 7 |
| 7 | 7 | 8 |
| 8 | 9 | 10 |
| 9 | 10 | 11 |
| 10 | 11 | 12 |
| 11 | 12 | 13 |
| 12 | 13 | 14 |
| 13 | 14 | 15 |
| 14 | 15 | 16 |
| 15 | 3 | 11 |
| 16 | 5 | 13 |
| 17 | 7 | 15 |
| 18 | 8 | 16 |

MEMBER PROPERTY AMERICAN

* TRAVERSE BEAMS

18 TABLE ST W10X26

16 17 TABLE ST W14X61

15 TABLE ST W16X77

* COLUMNS



1 TO 14 TABLE ST W14X42

MEMBER RELEASE

* RELEASE WEAK AXIS MOMENT ON TRAVERSE BEAMS

10 TO 17 START MY

10 TO 17 END MY

* RELEASE STRONG AND WEAK AXIS MOMENTS ON TOP MOST BEAM

18 START MY MZ

18 END MY MZ

SUPPORT

* BASES ARE FIXED

19 FIXED

* PROVIDE SUPPORT IN THE Z DIRECTION WHERE STRUTS ARE LOCATED

24 26 28 30 32 34 36 FIXED BUT FX FY MX MY MZ

CONSTANT

E STEEL ALL

DENSITY STEEL ALL

POISSON STEEL ALL

LOAD 1 DEAD LOAD

SELFWEIGHT Y -1.

JOINT LOAD

* AIR COOLERS

8 16 FY -26.

* 30" HEADER ON AIR COOLER

16 FY -2,376

* STRUTS

24 26 28 30 32 34 FY -.02

* AIR COOLER LONGITUDINAL SUPPORT BEAMS

8 16 FY -6.8

MEMBER LOAD

* FIREPROOFING - COLUMNS

1 TO 14 UNI GY -.244

* FIREPROOFING - TRAVERSE BEAMS

10 UNI GY -.202

16 17 UNI GY -.213

* UPPER LEVEL PIPING AND ELECTRICAL

17 UNI GY -.44 0. 12.

17 UNI GY -.4 12. 20.

17 CON GY -.036 3.

* MID LEVEL PIPING

16 UNI GY -.44

16 CON GY -.1276 2.0

16 CON GY -.1276 0.0

* LOWER LEVEL PIPING

10 UNI GY -.44

10 CON GY -.909 17.0

LOAD 2 FLUID LOAD

JOINT LOAD

* AIR COOLERS

8 16 FY -4.

* 30" HEADER ON AIR COOLER

16 FY -0.82

* UPPER PIPING LEVEL

MEMBER LOAD



17 UNI GY -.26 . 12.
17 CON GY -.7.67 3.
* MID PIPING LEVEL
16 UNI GY -.26
16 CON GY -.0.174 2.0
16 CON GY -.0.174 0.0
* LOWER LEVEL PIPING

10 UNI GY -.26
10 CON GY -.1.238 17.0
LOAD 3 LIVE LOADS
*AIR COOLER PLATFORMS
JOINT LOAD
8 16 FY -.2.0
LOAD 4 NORTH WIND
*AIR COOLER JOINT LOAD
JOINT LOAD
8 FY -.688
16 FY 0.688
8 16 FX -.6.820
MEMBER LOAD
* COLUMNS LEEWARD
1 2 UNI GX -.0.07
3 UNI GX -.0.07 . 2.0
3 UNI GX -.0.64 2.0 3.
4 TO 7 UNI GX -.0.64
* COLUMNS WINDWARD
8 9 UNI GX -.0.68
10 UNI GX -.0.68 . 2.0
10 UNI GX -.0.76 2.0 3.
11 TO 14 UNI GX -.0.76
JOINT LOAD
* LOWER STRUT LEEWARD
2 FX -.8.07
* LOWER STRUT WINDWARD
10 FX -.968
* MID AND UPPER STRUT LEEWARD
4 6 FX -.9.09
* MID AND UPPER STRUT WINDWARD
12 14 FX -.1.091
* AIR COOLER LONGITUDINAL SUPPORT BEAM LEEWARD
8 FX -.1.404
* AIR COOLER LONGITUDINAL SUPPORT BEAM WINDWARD
16 FX -.1.740
* LOWER LEVEL PIPING
3 11 FX -.829
* MID LEVEL PIPING
0 13 FX -.1.364
* UPPER LEVEL PIPING
7 10 FX -.1.273
LOAD 0 SOUTH WIND
*AIR COOLER JOINT LOAD
JOINT LOAD
8 FY 0.688



16 FY .0.688

8 16 FX 6.820

MEMBER LOAD

* COLUMNS LEEWARD

8 9 UNI GX .0.07

10 UNI GX .0.07 0.2.0

10 UNI GX .0.64 2.03.

11 TO 14 UNI GX .0.64

* COLUMNS WINDWARD

12 UNI GX .0.68

3 UNI GX .0.68 0.2.0

3 UNI GX .0.76 2.03.

4 TO 7 UNI GX .0.76

JOINT LOAD

* LOWER STRUT LEEWARD

10 FX .8.07

* LOWER STRUT WINDWARD

3 FX .9.68

* MID AND UPPER STRUT LEEWARD

12 14 FX .9.09

* MID AND UPPER STRUT WINDWARD

4 6 FX 1.0.91

* AIR COOLER LONGITUDINAL SUPPORT BEAM LEEWARD

16 FX 1.404

* AIR COOLER LONGITUDINAL SUPPORT BEAM WINDWARD

8 FX 1.740

* LOWER LEVEL PIPING

3 11 FX .8.29

* MID LEVEL PIPING

0 13 FX 1.364

* UPPER LEVEL PIPING

7 10 FX 1.273

LOAD 6 FRICTION

* DOUBLE LOAD TO ACCOUNT FOR REDUCING SY OF THE BEAM BY HALF.

* REMEMBER TO REDUCE BEAM END REACTION BY HALF IF LOADS ARE USED FOR

* VERTICAL BRACING DESIGN.

MEMBER LOAD

* UNIFORM PIPE FRICTION 10% OF OPERATING PIPE LOAD

10 16 UNI GZ .14

17 UNI GZ .14 0.12.

* CONCENTRATED LOAD USE 30%

* 36" DIA. FLR

17 CON GZ .922 3.

* 30" DIA. CWS

16 CON GZ 3.87 2.0

* 30" DIA. CWR

16 CON GZ 3.87 0.0

* 16" DIA. STM

10 CON GZ .040 17.0

LOAD COMB 7 DEAD + LIVE

1 1.2 1.3 1.

LOAD COMB 8 DEAD + NORTH WIND



1 .70 4 .70
LOAD COMB 9 DEAD + SOUTH WIND
1 .70 0 .70
LOAD COMB 10 DEAD + LIVE + NORTH WIND
1 .70 2 .70 3 .70 4 .70
LOAD COMB 11 DEAD + LIVE + SOUTH WIND
1 .70 2 .70 3 .70 0 .70
LOAD COMB 12 DEAD + LIVE + FRICTION
1 1 .2 1 .3 1 .6 1 .
PERFORM ANALYSIS
SECTION 0 . .70 0 .70 1 . ALL
PARAMETER
CODE AISC
* NOTE: IT IS IMPORTANT TO SUPPLY ALL REQUIRED PARAMETERS IF A

* CORRECT DESIGN IS EXPECTED.
* COLUMNS
KZ 1 .3 MEMB 1 2 8 9
KZ 2 . MEMB 7 1 4
LY 6 . MEMB 2 3 9 1 0
LY 6 . MEMB 4 0 1 1 1 2
LY 1 2 . MEMB 6 7 1 3 1 4
LZ 1 6 . MEMB 1 2 8 9
LZ 6 . MEMB 3 4 1 0 1 1
LZ 8 . MEMB 0 6 1 2 1 3
UNL 6 . MEMB 2 3 9 1 0
UNL 7 . MEMB 4 0 1 1 1 2
UNL 1 2 . MEMB 6 7 1 3 1 4
* BEAMS
CMY 1 . ALL
* CMZ DEFAULTS TO 0 . 8 0 & CB DEFAULTS TO 1 . 0 FOR ALL MEMBERS.
LOAD LIST 1 6 TO 1 2
PRINT SUPPORT REACTIONS
CHECK CODE ALL
FINISH